

	89014			89015			89016			89045			89063			89080		
	Wismar-Rothentor			Barnekow			Gägelow			Nakensdorf /Neukloster			Lübow			Neuburg-Steinhausen		
	Hs,n [kWh/m³]	Rhon [kg/m³]	CO² [mol- %]	Hs,n [kWh/m³]	Rhon [kg/m³]	CO² [mol- %]	Hs,n [kWh/m³]	Rhon [kg/m³]	CO² [mol- %]	Hs,n [kWh/m³]	Rhon [kg/m³]	CO² [mol- %]	Hs,n [kWh/m³]	Rhon [kg/m³]	CO² [mol- %]	Hs,n [kWh/m³]	Rhon [kg/m³]	CO² [mol- %]
Januar	11,588	0,7989	1,251	11,588	0,7989	1,252	11,557	0,7988	1,250	11,543	0,7964	1,233	11,555	0,7969	1,234	10,821	0,7574	2,606
Februar	11,644	0,807	1,455	11,644	0,807	1,459	11,645	0,807	1,467	11,637	0,810	1,560	11,657	0,810	1,575	10,910	0,759	2,302
März																		
April																		
Mai																		
Juni																		
Juli																		
August																		
September																		
Oktober																		
November																		
Dezember																		

Die Ermittlung der thermischen Energie **E** erfolgt mit dem Volumen im Normzustand **Vn** bzw. dem Volumen im Betriebszustand **Vb** und der Zustandszahl **z** sowie dem Abrechnungsbrennwert Hs,eff nach folgender Formel: **E = Vb x z x Hs,eff = Vn x Hs,eff**